

Mr. Prince stated that the new plans have not been sent to the Fire Department for their review.

Steve Aprilano asked how Mr. Schultz calculated the lowest water level in the pond. Mr. Schultz stated that he uses Monroe County regulations, his own experience and the soils in the area. Mr. Prince stated that when a pond is proposed for fire protection, that is a specific size that needs to be met. Mr. Schultz stated that he has to calculate for volume.

Mr. Prince asked the Board if it was okay to send the proposed plans to the Fire Department for their comments and concerns. Kris Schultz stated that he would update the plans per the letter he received from the Fire Marshal before he sends it out to the Fire Department.

The Board agreed that after the revision had been made to the Plans, Mr. Schultz can send them to the Fire Department for their comments and concerns. And after they have returned their comments and concerns, Mr. Schultz should come back to the Board with plans that have addressed all the comments and concerns.

Chairman Tod Ferguson asked that Mr. Schultz bring back a copy of the letter from the Monroe County Health Department. Mr. Prince looked through the file and found that the Town had a copy already in the file.

After Mr. Schultz had left, the Board requested that the plans be sent to the Town Engineer to have the Engineer confirm that the pond will hold the required amount of water. A discussion was held on the fact that droughts do happen and the Board wants to make sure that there is water in the pond if and when it is need for fire protection. The Board requested that the recording secretary send an email to Mr. Schultz asking that he forward the plans to Town Engineer for this review. She stated that she would.

A motion was made by Bob Pelkey and seconded by Steve Aprilano to accept the minutes of the July 17, 2012 meeting as presented. Motion carried unanimously 3-0 (Mike Reinschmidt and Mark Acker absent) .

Bob Prince stated that there seems to be some confusion as to the Fire Code Requirements for the Town and States. A review of the last meetings minutes was held. Mr. Prince stated that he would prefer to send his comments directly to the Board. A discussion was held on how to clear up the misunderstanding and Bob Prince gave a quick review of the Fire Code. The Board asked that Mr. Prince email his comments to them directly, when he submits them to the Building Department.

A discussion was held on accessibility of sidewalks and the placement of catch basins in relation to the sidewalks.

There being no further business, a motion was made by Steve Aprilano, seconded by Bob Pelkey to end the meeting at 7:55 pm. Motion carried unanimously 3-0 (Mike Reinschmidt and Mark Acker absent).

Respectfully submitted,

Maureen L. Werner
Recording Secretary